



防爆合格证

CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

证号 CE20.1242X
Certificate No.

产品名称
Name of Product
型号及规格
Type of Product
防爆标志
Marking
技术文件
Technical Documents
图号
Drawing No.
备注
Note (s)

振棒料位开关
Tube-11 1 2 3 4 A 5 6
Ex d II C T6/T5/T4/T3/T2/T1 Gb;
Ex tD A21 IP66 T80°C/T95°C/T130°C/T195°C/T290°C/T440°C
Q/JWVIBRATION03-2020
Tube-11.00; Tube-11.01
本证书备注内容详见附录

经对上述产品图样及技术文件的审查和样品的检验,其符合以下标准

By verifying the drawings and technical documents and checking samples, the product complies with the following standards

GB 3836.1-2010 GB 3836.2-2010 GB 12476.1-2013 GB 12476.5-2013

发给: 深圳计为自动化技术有限公司

Issued to:

本证失效日期: 2025-04-07

Date of Expire:

发证日期: 2020-04-07

Date of Issue:

中心印章
Center seal



中心主任
Director

刘弘光

国家防爆产品质量监督检验中心(天津)
(石油和化学工业电气产品防爆质量监督检验中心)
National Ex-Product Quality Supervision and Inspection Center(TianJin)

注: 本证仅对与送检样品一致的产品有效。

Note: This certificate is only valid for the products that are in accord with sample(s) tested and verified.

中心地址: 中国天津市丁字沽三号路 85 号

邮政编码: 300131

电话/传真: 022-26651066 / 26689116

Center Add: No.85 No.3 Road DingZiGu Tianjin China Post code: 300131

Tel/ Fax: 022-26651066/26689116

E-mail: pcec@pcec.com.cn

<http://www.pcec.com.cn>